

NovaTech®

Ø 0 0-00 XXXXXXXXX on,DR2_0250.DAT - 17/02/2012 - 07:00:00.312 - Primary - (Peak T IN E.Z - (120217,065 9421338,0,345_66kV_Tra er_IED,DI De er, DI Lo n,DI O ⊻iew ≅ Values Window Help ➡ O Back Pries R B R O T Windo #5 [] 02/17/2012 0#31-16 PM () () 🌾 🎋 🙀 · 🗤 |\$| |\$j | 🌾 ୍ର୍ ⇔ ⇔ 3 ΘX 2 hours (appended) Nine required measurements plus status points 345/66kV Tra DIO#0 Output DIO#0 Output 4 Virtual Output 4 GOOSE Binary In GOOSE Binary In Fri - 17/02/2012 06:59:59.421338 Delta X: 833.000 ms (49.980 cyc @ 60 hz) fs: 6.002 Hz AS: ++ Delta Y: No Ba



DME and NERC PRC-002-2



NovaTech_®

This page intentionally left blank.



NovaTech®

Table of Contents	Page
ntroduction	4
NERC PRC-002-2 and the Need for Disturbance Monitoring Equipment	4
Bitronics® 70 Series	6
Summary: Bitronics 70 Series Compliance to PRC-002-2 Requirements	8
Customer Experience Using 70 Series for PRC-002	10
Example Configuration	16
NovaTech Utility Systems and Services	28



Introduction

The North American Electric Reliability Council (NERC) has defined standards for disturbance monitoring and reporting requirements for transmission and generation systems. The primary standards are PRC-002-1 and PRC-018-1 (both approved August 2006) which are to be replaced by PRC-002-2 when approved. These standards, or versions from the eight regional reliability councils that are charged with compliance enforcement of the NERC standard, establish requirements for installation of Disturbance Monitoring Equipment (DME).

DME is required to be installed at specific places within the generation and transmission infrastructure. DME capable of monitoring and recording system data pertaining to a wide variety of system or equipment disturbances and must provide fault recording, dynamic disturbance recording (DDR), and sequence of event (SOE) recording. Bitronics 70 Series monitoring and recording IEDs (intelligent electronic devices) meet the requirements for DME within the current PRC-002-1 / PRC-018-1, and PRC-002-2 in all of these areas.

NERC PRC-002-2 and the Need for Disturbance Monitoring Equipment (DME)

Key Elements of the Standard

NERC PRC-002-2 is attempting under "Project 2007-11 Disturbance Monitoring" to standardize the regional reliability requirements concerning Disturbance Monitoring Equipment (DME). No date for approval has been established and the project status is in "Informal Development."

The purpose of the project is to establish requirements for installation of DME and reporting of disturbance data to facilitate analyses of events and verify system models.

This project involves modifying two standards:

- PRC-002-1 Define and Document Disturbance Monitoring and Equipment Requirements
- PRC-018-1 Disturbance Monitoring Equipment Installation and Data

The project involves replacing "fill-in-the-blank" requirements currently assigned to the Regional Reliability Organization, with requirements for North America that are applicable to other functional entities. As envisioned, each region will supplement PRC-002-2 with a regional standard that will include additional requirements.

The differences in PRC-002-2 are minimal compared to the already approved PRC-002-1 and PRC-018-1 standards so even if PRC-002-2 is not approved, existing requirements established under the two approved standards are driving compliance.

PRC-002 (-1 and -2) requires DME on nearly all lines of 200kV and up, as well as generation connected to the grid at 200kV and above (in general, for transmission substations at 200kV and above and generation connected to the grid at 200kV and above with single generation units of 500 MVA or total nameplate capacity of 1500 MVA or greater). Prior standards generally required DME only on EHV lines (345kV and up) and the nature of the recordings also differed.

PRC-002 describes three recording functions in detail:

- Sequence of Events (SOE) logging
- Fault Recording (FR)
- Dynamic Disturbance Recording (DDR)

While the first two are more widely available, DDR function is comparatively novel, more demanding, and generally only available from newer DFRs such as 70 Series.

Disturbance Monitoring Equipment for PRC-002



Focusing on DDR, PRC-002-2 requires utilities to:

- Capture a continuous recording of up to nine measurements per line (per-phase volts and amps, total MW and MVARs, and frequency) with high resolution (at least 960 samples per second to calculate RMS quantities and at a rate of at least six times per second to store calculated RMS quantities) and make it available in Comtrade (C37.111) format using the "long file naming convention" (C37.232).
- Preserve a continuous record for ten days.
- Archive disturbances indicated as being of interest (Regional Reliability Organization-identified events) for at least three years.

Although some modern protective relays may be able to be configured to provide the SOE points and waveform capture required for PRC-002-2, none provide the combination of continuous recording and memory storage required by DDR.

While the existing requirements are for 200kV and above, NERC has provided a draft definition of the Bulk Electrical System (BES) under Project 2010-17 that defines applicability and exceptions at the **100kV level and above**. So while not a certainty, there exists the possibility that the PRC-002-2 could be extended below 200kV, and in fact Northeast Power Coordinating Council (NPCC) for one is looking to apply PRC-002 to BES levels.

Why This Matters Now?

Being able to comply with NERC and various regional reliability council requirements is becoming increasingly important for transmission and generation operators as the time to comply in some areas is already at hand. For example, the Regional Reliability Organization Reliability First Corporation approved PRC-002-RFC-01 in May 2009, meaning that partial compliance began in 2010, with the majority of compliance required by 2014. Because the standards require DME in some cases where no or minimal recording capabilities existed (installations starting as low as 100kV) operators are in need now of cost-effective solutions that meet the current and upcoming standards.



70 Series two-hour continuous DDR record viewed in Wavewin® with time sync status shown

NovaTec



Bitronics 70 Series



The 70 Series of IEDs consists of the M87x modular family and the M57x compact family. The M87x family provides greater flexibility and increased I/O capability in a modular design, while the M57x provides a more economical option with all hardware selected and built in at time of order. With multi-mode recording and ability to make high speed, high accuracy measurements, both IED families provide information necessary to analyze:

- Network faults such as short circuits, underfrequency, over/under voltage, etc.
- Reactions of the protective devices
- Dynamic response of the network
- Long-term trends
- Substation equipment performance
- Sequence of Events time stamped to 1ms

70 Series serves SCADA metering and automation, control, and disturbance recording applications in the substation including PRC-002 compliance. The 70 Series IEDs can provide automation where electromechanical relays are still employed or can complement digital relays by providing additional recording capability while providing enterprise-wide access to important event files without jeop-ardizing the security of the protection system. The split-core CT option, described below, simplifies retrofit of 70 Series in these applications and removes the need for an outage.

Memory options up to 512 MB easily allow the recording and storage requirements of PRC-002-2 to be met. 70 Series IEDs provide features to reduce installation costs for faster PRC-002 compliance including:

- IEDs sized for single or dual line for maximum flexibility and scalability
- Wide-range temperature and universal power supply and wiring
- Flexible mounting
- Configurable ports and protocols
- Split-core CTs that don't require an outage to break into existing 5A circuits

The split-core CTs are available for the M571. Three individually calibrated, spring-tension mounted CTs are provided replacing the internal CTs. They are 5A nominal and linear to 100A and give the same accuracy as with the internal version.



70 Series Detached Displays

The 70 Series family of detached displays is available to provide local indication of measured parameters from the M87x and M57x IEDs.

The M570DA is used exclusively with the M57x from which it is powered. The M570DA is mounted up to 15 meters from the IED.

The M870D is self powered, allowing up to 15 displays to be connected to a single M57x or M87x IED. M870D can be installed up to 1000 meters from the IED.

70 Series Software

70 Series application software is available for use with M87x and M57x family of IEDs.

70 Series utility software, which consists of the Configurator used for configuration and BiView used for commissioning and file retrieval, are included with any M87x or M57x IED order. Within BiView, the Retriever software allows the user to set up via a Windows task manager, automatic transfer and storage of record files. Selected record files can be automatically retrieved daily, weekly, or monthly, or immediately upon demand.

Wavewin[®] Bitronics[®] software is available for viewing and managing Comtrade record files. This software is licensed from Softstuf, Inc.



Typical wiring of Bitronics M571 with Split-Core CTs in PRC-002-2 application

NovaTec



Summary: Bitronics 70 Series Compliance to PRC-002-2 Requirements

Bitronics 70 Series IEDs are compliant with PRC-002 existing and upcoming standards in all three recording areas. With memory option up to 512MB there is more than adequate storage to meet the required number of recordings. They offer the ability to record both the time sync status as well as the time sync error for the DDR. The biggest advantage for a 70 Series recorder is as a one-unit-per-line device it can be retrofitted into existing substations much more easily and cost effectively than adding a full-size DFR. The following table summarizes the requirements and Bitronics 70 Series compliance.

PRC-002-2 Requirement for SOE Equipment

Requirement	Reference	Compliance	Notes
Record opening and closing of breaker auxiliary contacts	R1, R2	\checkmark	Up to 48 digital inputs per line using M871
Record the time stamp to within four milliseconds of input received for change in circuit breaker position	R3	\checkmark	Input Delay Time (from termi- nals): <100μs

PRC-002-2 Requirement for Fault Recording

Requirement	Reference	Compliance	Notes
Record 3 phase-to-phase or phase-to-neutral voltages on monitored line or bus or on Generator Step-up (GSU) trans- formers	R4.1, R5.1, R5.4	\checkmark	Each IED can record all three phases on a line. M87x can record neutral current, M57x records residual. Mx72 can record two 3-phase lines.
Record three phase currents and the residual or neutral cur- rents of each monitored line and transformer or on Generator GSU transformers	R4.2, R5.2, R5.3	\checkmark	
Record at least two cycles of pre-trigger data	R6.1	+	Pre and Post-trigger record
Record post trigger of at least 50 cycles or first three cycles of an event and the final cycle of an event	R6.1	+	cycles.
Record at a minimum rate of 16 samples per cycle	R6.2	+	128 samples per cycle typical, 256 samples per cycle max.

PRC-002-2 Requirement for Dynamic Disturbance Recorder (DDR)

Requirement	Reference	Compliance	Notes
Record voltage and current from at least one phase (on the same phase) for all transmission lines at 200 kV or above	R7.1, R8.1, R9.1, R10	\checkmark	Each IED can record all three phases on a line. M87x can
Record at least one phase-to-neutral or phase-to-phase volt- age of the high or low side for each GSU transformer and at least one phase current (same phase as voltage)	R7.3, R8.3, R9.1, R10	\checkmark	record neutral current, M57x records residual. Mx72 can record two 3-phase lines.
Record frequency (at least one at the required substation)	R7.2, R8.2, R10	\checkmark	
Record power and reactive power (MW and MVAR) on a three- phase basis (per each monitored line or transformer)	R7.4, R8.4, R10	\checkmark	
Sample data at a rate of at least 960 samples per second to calculate RMS electrical quantities	R9.2, R10	+	7680 samples per second (60 Hz) used for all RMS calculations
Store calculated RMS values of electrical quantities at a rate of at least 6 times per second	R9.3, R10	\checkmark	Resolution configurable up to 10 times per second
Fault Recording and DDR data must be capable of being viewed and analyzed as COMTRADE (IEEE Std. C37.111-1997 or successor) files	D1.5.1	\checkmark	Stored in Comtrade format on IED. No off-line conversion required.
Data files shall be named in conformance with IEEE C37.232, Recommended Practice for Naming Time Sequence Data Files	D1.5.1	\checkmark	

NovaTec



Customer Experience Using 70 Series for PRC-002

In 2009 Baltimore Gas & Electric (BGE), completed Disturbance Monitoring Equipment (DME) installation at Graceton substation. This project was part of BGE's overall plans to address NERC Standard PRC-018 requiring all transmission owners have or install DME in accordance with the Regional Reliability Organization's (PRC-002) requirements.

Goals of the Graceton project were to design and install a system that would not only meet the PRC-002-RFC requirements, but also realize design templates for future DME work and address some aging infrastructure issues.

The basic project achievements included:

- Met the PRC-002-RFC-01 requirements.
- Created templates for future DME work.
- Reduced physical control wiring.
- Reduced aging infrastructure and maintenance.
- Installed a distributed recording solution that cost less than a conventional approach.

BGE falls under the Regional Organization sanctions of Reliability First Corporation (RFC). Their standard PRC-002-RFC-01 requires that DME be installed to monitor three-phase currents, three-phase potentials, and breaker status on all lines and transformers in substations 200KV and above. Installed DME must be capable of digital fault recording (DFR), dynamic disturbance recording (DDR) at locations meeting specific criteria, and sequence-of-events (SOE) recording.

The Graceton Substation is a 230 KV substation which terminates four transmission lines and a 230/115 KV transformer and was therefore affected by this standard. Graceton Substation did not have any DME equipment installed and design concepts were put forth to address the issue.

The team approach to resolving the PRC-002-RFC requirements was unique in that it chose a design concept of distributed recording, where multiple pieces of installed equipment were linked together via communications to form a complete recording system.

The equipment selected was Bitronics 70 series IEDs (M871 and M571) which were installed on every line circuit. To use the IEDs in distributed recording each IED was connected to an Ethernet switch allowing communication of GSSE (UCA GOOSE) messages. If an IED recognized a system event it would cross trigger all other IEDs to record at that instant, thus capturing all power system reactions at the substation.





Bitronics M571 recorders used for PRC-002 compliance mounted in back of cabinet

	-								_
A Democratic	GG	SSE (Virtual I/O)							
User Defined Measurement Names		GSS	E (UCA GOOSE) Virtual Inputs (Receive)						
Fill Instrument Transformer Fault Location Line Settings Measurements		Device Name	Point Type	Point	On Value	Off Value	Defau Value	t SOE Entry	1
Demands	10	MFM-500-1-HS	User Status 💌	50	10 🔳	11 💌	10	• •	
W Apparent Power (VA)	11	MFM-500-2-HS	User Status	50	10 -	11 -	10		1
Harmonics	12	MFM-500-3-HS	User Status	50	10 💌	11 💌	10		1
Communication	13	MFM-5052	User Status	50	10 💌	11 💌	10		1
Port Assignments	14	MFM-5053	User Status	50	10 💌	11 💌	10	• •	1
XSI Protocols	15	MFM-2340	User Status	50	10 💌	11 💌	10		1
UCA Time Sync	16	MFM-500-1-LS	User Status	50	10 💌	11 -	10		1
1 IRIG-B	17	MFM-500-2-LS	User Status	50	10 -	11 .	10		1
4 DNP	18	MFM-500-3-LS	User Status	50	10 -	11 .	10		1
E Triggers and Alarms	19	MFM-500-4-LS	User Status	50	10 -	11 -	10		1
G GSSE (Virtual I/O)	20	MFM-2342	User Status	50	10 -	11 -	10	• •	1
Automatic Notification settings	21	MFM-2338	User Status	50	10 -	11 💌	10	• •	1,
Kecorang Hodes Secorang Hodes Secorang Hodes Waveform			Virtual Output (Send)						
- 👌 Trending 🖌 🖌		GSSE Tx Name MFM-5051	Multi Cast	Address				_	

Setup of virtual inputs for GSSE (UCA GOOSE) cross triggering

NovaTe



NovaTech

le Help				
🛶 Identity 🔥	🕹 UCA Time Sync			
Passwords User Defined Measurement Names Hardware Hardware Fustument Transformer Fault Location Line Settings Maasurements		UCA Network Time Syn	c	
- Will Apparent Power (VA)		Slave Address (MAC or IP)	Update Rate (sec.)	^
- Picker	01 192.168.208.2	1	60	13
Communication	02 192.168.208.2	2	60	
Detached Display Port Assignments	03 192.168.208.2	3	60	
Real Protocols	04 192.168.208.2	4	60	
Synchronization	05 192.168.208.2	5	60	1
W IRIG-8	06 192.168.208.2	6	60	v
Triggers and Alarms		Slave Configuration		
Recorder Inggers GSSE (Virtual I/O) G3 Automatic Notification settings	Latency History 10	± Latency Range 50 ± in μ	sec SOE Entry on Signal Acquisition	
Disturbance View Waveform Control of the second seco	Therefore you can ha	nis unit is able to be a master and a slave at t we another device time sync this unit, and hav	he same time. re this unit time sync other (units

Setup of UCA Network Time Sync which allows one IED to act as a time sync master

Part of the project required a mechanism to retrieve the individual meter records and compile the information. BGE installed a secure work station that used vendor supplied software. The software allows the downloading of records and the sinusoidal traces of a recorded event from a group of meters can be combined to form a DFR view of the event at the station.



WAVEWIN BITRONICS			
iles Data Channels View Values Window Help			
Exit System 🗏 🔟 🗟 🔾 Back 😂 Files		06/23/2	2010 10.27.05 PM
Deter 📽 • 🗿 📴 📴 🔂 산 전 %, 역, 역, 수수 👘 (히 (히) 🀲	※ 李 海 👹・		
WR1_000001.dat - 04/06/2009 - 04:10:35.974 (Peak Type)			
CH 🕢 📃 📃		RMS	IndPeak 0
	.71L3TM 2323Webage leput A1 Overn	121171.309	-171039.764
	_714.3TM 2223Voltage Input B1 Chann	133180.515	189658.320
		132051.253	187070.109
	_714.31M 2323 Current Input A1 Channel	1225.006	1737.680
	_714.3TM 2323-Current Input B1 Channel	649.064	-905.941
	_714.3TM 2323 Current Input C1 Diarren	1027.234	-1430.523
	.714.11M 2303Voltage Input A1 Diam	120224.161	-171336.230
		132799.285	187778.352
	_714_1TM 2303Voltage Input C1 Diamy	131535.187	196547.983
	_714,11M 2303 Current Input A1 Channel	643.298	916.294
	_71-L1TM 2303-Current Input B1 Channel	362.867	-525.308
	_714,11M 2303-Current Input C1 Duarne	587.157	-826.563
	_14,21M 23014/otage input A1 Charree	58382.092	-62137.830
	14.21W 2301Votage Input B1 Channe	63075.741	89136.832
	14,27M 23014/stage input CI Charre	62404.313	88164.161
	_142TM 2301-Current Input A1 Charred	401.816	-566.342
"MAAAAAAAA	14,21M 2301 Current Input B1 Channel	348.167	-498.009
	_14,21M 2301-Current Input C1 Charred	397.671	568.449
19,40 m 40,20 m 40,00 m 18,40 m 18,40 m 40,00 m 40,00 m	An ma		

Combined waveform capture from multiple 70 Series IEDs

Implementing the integrated design and commissioning the equipment went seamlessly in very little time due to careful planning and the use of developed setting templates.

Other highlights and benefits included the ability to report fault distance on the transmission circuits back to the control center saving analysis time. The installed IEDs also allowed BGE to retire aging analog transducers, upgrade reported analogs to three phase digital readings and report billing metering on two of the interconnect lines. **Disturbance Monitoring Equipment for PRC-002**



NovaTech



Fault Location setup in 70 Series Configurator

BGE realized savings by not installing expensive DFR equipment in using the distributive recording approach and enhanced station metering as an additional benefit.



Cost Reductions

The innovations detailed in the previous section led to reductions in field labor and time. The DME project has been received well by BGE field personnel saving maintenance costs by replacing analog transducers and meters with digital equipment thus extending maintenance intervals. The distributed fault recording design has also saved thousands of dollars compared to installing a conventional digital fault recorder solution.

- Substation Equipment Enhancement The new DME equipment that was selected, the Bitronics 70 Series, has enhanced substation metering. The upgrade from analog to digital has provided more accurate metering for both local and remote reporting. The functionality of the equipment also allows for fault distance reporting on the transmission circuits, saving some up front analysis time.
- Reduction of Aging Infrastructure BGE's integrated design and carefully selected equipment has allowed the retirement of analog metering transducers and analog meters within the substation.



70 Series Installation allowed removal of analog metering

NovaTe



PRC-002 Solution for Natural Gas Plant

Recently, Exponential Engineering of Fort Collins, CO was asked to develop a PRC-002 compliant solution for an 800 MW natural gas plant in Texas. They utilized the M871 in a Hoffman enclosure as shown in the picture below.



Exponential Engineering design of single line DME for PRC-002

Disturbance Monitoring Equipment for PRC-002



Example Configuration How does the DDR work?

Help							
Fault Location Line Settings	🖄 DR01 Record	er					
Measurements			Disturbar	nce Recorde	er 1 (Triggered)		
We Apparent Power (VA)		Mea	surement to Rec	ord	Min/Max Rec	orded (Primary)	^
- Plicker	1	RMS Volts A 1		•	0 / 6	00 -	
Harmonics	1	DMC Velte R 1		-	0/0	00 -	
J Communication	2	RIVIS VOILS D I			076		
Detached Display	3	RMS Volts C 1		•	0/6	•	
	4	RMS Amps A 1		<u>•</u>	0 /	10 🗾	
Kunchronization	5	RMS Amps B 1		-	0/	10 🔳	
UCA Time Sync	6	RMS Amps C 1		-	0/	10 💌	
- & IRIG-B	7	RMS Watts Total	1	-	-3.000 /	3 000	_
SNTP =	<u> </u>						
DNP		Measurement	Type Filter			Aeasurement Filter	
E Triggers and Alarms		us V Demands	Harmonics	Ratios	Amps Volts	Power Miscel	laneous
Yo Recorder Triggers		Flash Drive Usage	Typical #	COMTR	ADE File Type	Cycles per Sample	10 -
Automatic Notification setting		0	of Files	 Binary 	ASCII	Set alarm when space used :	>= 75
	Disturbance I	0	50 % 338			Samples of Pre-Trigger	6
Recording Modes	Disturbance 2	0	50 % 338	Measu	irement Type	Samples of Post-Trigger	21,650
Disturbance	Waveform 1		0 % 0	Instantaneous	🔘 Min & Max & Avg	Allow Re-Triggeri	ng 📃
	Waveform 2		0%0				
DR02 Recorder	Trending		0 % 0	When Sto	orage Space Full		
Waveform -		Unused	0 %	Stop Recording	Overwrite Oldest		

DDR uses both Disturbance Recorders (DR1 and DR2)

Configuration of the Disturbance Recorders used in the DDR

- 1. DR1 and DR2 alternates recording during successive hours. This is done to avoid any loss of data during the time when one recorder would end and the other start. Manageable files of one two hours each are created, making locating fault files simpler.
- 2. The resolution of 10 Cycles per Sample (see arrow) at 60Hz produces six samples per second on the recording required by PRC-002.
- 3. Each RMS measurement is calculated by a Digital Signal Processor operating many times faster than the minimum sample rate needed for PRC-002 compliance.
- 4. A record Length of 21,650 samples (see arrow) at 6 samples/sec = 1 hour plus a few seconds of overlap at each hour transition between recorders.
- 5. Ten days of on-board storage (the PRC-002 requirement) of 24 one-hour-long recordings requires a capacity of only 240 files. The recorder in the above image is indicating 338 DR1 + 338 DR2 records = 28 days capacity on a 256MB CF card. A 512MB CF card is also available if more memory is desired.



DR1 and DR2 alternate by using "Periodic Triggers" which were added to accomplish a continuous 7x24 recording

Help													
Demands ^ 🕅	Recor	der Triagers											
-W Apparent Power (VA)			т	riggers	5								
- Plicker	_							<u> </u>					
Harmonics	Event	Measurement to Trigger On		Sign	Value	Hysteresis	Min Duration (ms)						
- y Communication	1	Periodic Trigger 1	-	=	1	N/A	0						
Port Assignments	2	Periodic Trigger 2	•	=	1	N/A	0						
+ XSI Protocols	3	SNTP Time Sync	-	=	1.*	N/A	0						
Synchronization	4	Time Sync Error (msec)	-	< •	2	0	0						
- de UCA Time Sync	-	Vistual Output 1	-	-		AL/A							
🎉 IRIG-B	0	Virtual Output 1	_	-		N/A	0	-					
- d SNTP	10	Measurement Type Hiter	Ratio		Me Amoe Voite	Power	Mecalanaous						
					C reps	(L) roma	- maccing loods						
St. Triggers and Alarms	[] Wa	veform Recorder 1 Reset Meas	TO Series	Action	tor v2.07								2
E GSSE (Virtual I/O)	[]Wa	veform Recorder 2	70 Series	oningura	(OF V3.07								-
- Automatic Notification setting	V Dist	urbance Recorder 1	Eile He	lp									
-*& Timers	[Dist	urbance Recorder 2		Demar	nds	A SReco	rder Triggers						
Recording Modes	[1] Digi	tal Output	-6	Appare	ent Power (VA)		55		Т	rigger			
Disturbance	[]] Vitu	al Output Automatic N	e -	Flicker						iggen			
DR01 Recorder	SOE	Entry		Harmo	onics	Even	t Measu	urement to Trigger On		Sign	Value	Hysteresis	Min Duration (ms
DR02 Recorder	Res	et Measurement	€.9	ommuni	cation	1	Periodic Trigger 1		-	=	1.**	N/A	0
Waveform	Auto	omatic Notification	-0	Detach	ed Display	2	Periodic Trigger 2		•	=	1.**	N/A	0
The Voltage Structuration Threshold	E Fau	t Analysis Message		Port As	ole	1 3	SNTP Time Sync		-	=	1.*	N/A	(
- Voltage Pluctuation Thresholds +				wnchroni	zation		Time Sunc Error /	(meac)	-		2	0	
				UCA T	ime Sync	4	Time Sync Error ((msec)		-	2	0	
anges Will Not Take Effect Until the D	Device is	s Rebooted	1	RIG-B		5	Virtual Output 1		-	=	1.	N/A	
				SNTP			M	leasurement Type Filter			Me Me	sasurement Filter	-
				DNP			V Instantaneous	Demands V Harmonice	Rabo	\$	V Amps Vots	Power	Miscellaneous
			₽-4€	riggers an	nd Alarms			Denset Man		Action	Directed Output	16	and O and
				B Record	ler Triggers		aveform Hecorder 1	rveset mea	SUPERIORI		Digital Output		coort
				GSSE (virtual I/O)		averorm Necorder 2			× .			Send GSSE
				th Timers	add Notification setting		stubance Recorder 1		Fault Dista	ance			Point Type Point
			- @	Recording	Modes		atal Outout				Latch On		
			6	C Disturb	oance		tual Output	Automatic N	atification		Recordere		Value Oli Value
			T.	DR	01 Recorder		E Entry				Trigger Type		
				DRI	02 Recorder		net Mann remark			-	Edge Level	Logic	
			⊕-\	Wavefe	orm		tomatic Notification		SOE				No Logic
				Trendi	ng		at Analysis	Message				Multiple T	riggers OR togeth
			100.0	T Valtaa	e Eluctuation Threshold		nam or a marginitia						AND toget
				- voitage	e riuctuation miesnoiu								

Use of Periodic Triggers for continuous recording

DR1 and DR2 run in alternate hours in order to insure no interruption in data at the transition between the end of one record and the beginning of the next.

One-hour-long records occupy about 200kB of memory each and are a convenient interval length because of the time it takes to download files, the ease of locating exactly the recordings that are of interest, and because the performance of most commercial Comtrade viewer software (such as Wavewin) begins to suffer if more than a few hours are appended into a single continuous record.

Disturbance Monitoring Equipment for PRC-002

DME and NERC PRC-002-2 17



Four independent Periodic Triggers are provided. Only two are required to accomplish the DDR function.

e <u>H</u> elp		
Protocols	10 Timers	
Registers	Ti	mers
□ → DNP → DNP Point Assignments	Periodic Trigger 1	Periodic Trigger 2
DNP IP Settings	Timer Period 2 + Hr 0 + Min	Timer Period 2 + Hr 0 + Min
UCA/IEC61850 Synchronization UCA Time Sync WirkIG-B	Start Time 0 🚖 Hr 0 🚖 Min	Start Time 1 🚖 Hr 0 🚖 Min
	Periodic Trigger 3	Periodic Trigger 4
GSSE (Virtual I/O)	Timer Period 0 🔄 Hr 0 🗢 Min	Timer Period 0 VHr 0 Min
Control Contro Control Control Control Control Control Control Control Control Co	Start Time 0 🚖 Hr 0 🚖 Min	Start Time 0 ⊕ Hr 0 ⊕ Min
Trending Voltage Fluctuation Thresholds		

Two Timers used for DDR staggered by one hour

On the preceding page we saw that Periodic Trigger 1 initiates DR1 and Periodic Trigger 2 initiates DR2. The image above shows how the two periodic triggers are configured.

Periodic triggers operate as a "soft" binary point that changes state, dwells for about ten milliseconds, then returns to its initialized state.

Observe how both triggers have a two-hour interval, that is, they fire every two hours, but the start times are staggered by one hour, so the one trigger operates in each alternate hour.

Noval



By assigning the same name to PT1 and PT2, the Disturbance Records DR1 and DR2 can be appended into multi-hour continuous recordings

le <u>ri</u> eip		
	💆 User Defined Meas Names	
Passwords User Defined Meas Names	User Defined Mea	asurement Names
Hardware Instrument Transformer	Default Measurement Name	User Defined Measurement Name
Fault Location Line Settings	Average Amps Bus1	
Measurements	DNP Active Connections	
	Periodic Trigger 1	Clock Trigger
	Periodic Trigger 2	Clock Trigger
	Periodic Trigger 3	
- Detached Display	Periodic Trigger 4	
Port Assignments	RMS Volts A 1 Harmonic	
Synchronization	RMS Volts B 1 Harmonic	
	RMS Volts C 1 Harmonic	
SNTP	RMS Volts AB 1 Harmonic	
Trigger and Alarms	RMS Volts BC 1 Harmonic	
Recorder Triggers	RMS Volts CA 1 Harmonic	-
GSSE (Virtual I/O)	Measurement Type Filter Channels Instantaneous I Demands I Hamonics I Rat	Measurement Filter tios I Amps I Volts I Power I Miscellaneou

Using Defined Measurement Names makes it easier to append separate records

The trigger (either PT1 or PT2) appears as one of the binary traces in each Comtrade file. That is PT1 appears in each DR1 file and PT2 appears in each DR2 file. Since the same trace has a different name in DR1 and DR2, the two recordings would not normally be able to be appended by most Comtrade viewer software (like WaveWin). But by manually assigning the same name to both traces, users can string together up to four Comtrade files into a single contiguous recording.

Note, because of the large amount of data, the smooth performance of Comtrade viewer software can be degraded by appending more than a few one-hour-long records together.

Disturbance Monitoring Equipment for PRC-002

DME and NERC PRC-002-2 19





Logic (1): Local indication that the recorder is active.

Local indication (LED lights on front of M871 unit) is optional, but very useful feedback for operators.



Logic (1): Local indication that the recorder is active.

LED on Digital I/O Module indicates that DDR is functioning

Novalec

Setting up digital output for visual evidence that recorder is active





Logic (2): Local indication of time sync status.

Using AND Logic to determine time sync is active and within spec

Event 1 is a binary condition that indicates when an SNTP server is connected and the M871 is receiving a valid signal (does not distinguish accuracy of the server).

Events 2 and 3 are analog measurements that measure the difference between the clock on the SNTP server and the clock on the M871. PRC-002 requires time sync to be +/-2ms or better.

Event 1, 2 and 3 all have the same configuration: Virtual Output 1 will operate only when the AND logic is satisfied.

On the next page, the results of Virtual Output 1 operating is described.

NovaTech





Logic (2): Local indication of time sync status.

Setup for local indication of time sync status

When the AND-logic is satisfied, Virtual Output 1 operates, causing the Digital Output 4 on Card 0 to operate, closing the contact and illuminating an LED for positive indication the clock on the M871 is synchronized with the SNTP server.



Logic (2): Local indication of time sync status.

LED showing time sync active and within spec

NovaTec

Card 0, Output 4 = SNTP is active AND $\triangle t < 2ms$.



What does it look like?



Single record of nine measurements required in DDR plus status points

Note the following:

- 1. Traces are RMS, not oscillographic: it's a DDR, not a fault record.
- 2. Digital Trace #16 is the sync status, the virtual output that represents the result of the AND-Logic described in the previous page. Trace #14 mimics #16 because we are using the virtual point to drive a digital output contact (lights an LED on the panel) as an outward indication of sync status.

Disturbance Monitoring Equipment for PRC-002



Data Channels View Value	es <u>W</u> indow <u>H</u>	elp												
<u>O</u> pen	Back	🗁 Files 🛛	🕮 Devices	Stations	🥜 Faults						02/17/20	012 04:17:56 PM		
Append Open <u>Files</u>	Disca	rd Common Tim	es	Q .	e) (h	\$ \$	3 1 1	20-	游 🔅	∜ວ 📅 - 🐴	. ·			
Merge Open Files	<u>B</u> ack	to Back				100 (001 0 00 0		(0					i ,	
View Raw Data File	ionnei_izo	or Description, D	rowner, brei	eation,DKL_	0250.DAT - 17	/02/2012 - 08:0	10:00.011 - Ph	mary - (Pea	k Type)	Title	1	BMS DIX		
Save As	•													
Window Properties	-									RMS Volts B 1	2	207061.184		
Researched Channels	1000 miles	<u>المرامية معربية المارية</u>	سيبليدين		لغاريية بيغيبها	يسبل بنيسه	يقدين فيتحاد تروينه		****	RMS Volts C 1	2	204805.441		
Summan	F2									RMS Amps A 1 BMS Amps B 1	2	226.095		
30 <u>m</u> mary				and the second second	*****					RMS Amps C 1	2	221.879		
Print	,									RMS Watts Tot	al1 9 J1 1	34439479.125		08.00
Printer Setup										Frequency Volts	A1 5	59.991		00.00
Email Active File					,					Time Sync Error	(msec) 3	3.627		
Close File Ctrl-	F4	840	10	50 ' ' '	1280	1470	1680	1890	21	00 A 345/66kV Tr	ansformer 34	5kV CB "a" swit →		
<u>c</u> ioserne can										A DIO#0 Outpu	#1 #2			
										A DIO#0 Outpu	# 3 # 4			
							_			N Virtual Outpu	t4 milenut led	2		
N.										GOOSE Bina	ry Input - Ind	4 🚽		
120217 065050421338 0 345 664V	Transformer IED	DI Description D	I Owner DI L	ocation DP2	0250 DAT - 17	/02/2012 - 07/0	10-00 312 - Pri	many - (Dea	k Tune)	GOOSE Bina	ry Input - Ind			
120217,065959421338,0,345_66kV	_Transformer_IED	,DI Description,D	I Owner, DI Lo	ocation,DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)		ry Input - Inde			
120217,065959421338,0,345_66kV	_Transformer_IED	,DI Description,D	I Owner, DI Lo	ocation,DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	InstPeak	Phase	4 v InstV • ×	<	
* 120217,065959421338,0,345_66kV •	_Transformer_IED	,DI Description,D	I Owner, DI Lo	ocation,DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	InstPeak 205274.209 204693.215	Phase -0.000* -0.000*	4 ▼ InstV •× 205274.209 204693.215	<	
* 120217,065959421338,0,345_66kV.	_Transformer_IED	,DI Description,D	I Owner, DI Li	ocation,DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	 InstPeak 205274.209 204693.215 205427.102 	Phase -0.000* -0.000* -0.000*	4 ▼ InstV •× 205274.209 204693.215 205427.102	. ∢	
120217,065959421338,0,345_66kV,	_Transformer_IED	,DI Description, D	I Owner, DI Li	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	✓ InstPeak 205274.209 204693.215 205427.102 225.220 225.220 225.220 226.220	Phase -0.000* -0.000* -0.000* -0.000* -0.000* -0.000*	4 v InstV • × 205274.209 204693.215 205427.102 225.220 220.022	<	
▲ 120217,065959421338,0,345_66kV.	_Transformer_IED,	, DI Description, D	I Owner, DI Li	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	 ✓ InstPeak 205274.209 205427.102 220.032 220.032 220.642 	Phase -0.000* -0.000* -0.000* -0.000* -0.000* -0.000* -0.000* -0.000*	Instv Instv 205274.209 204593.215 205427.102 225.220 220.032 220.032 220.642 220.642	< ≺	
▲ 120217.0659595421338,0,345_66kV, ■ •	_Transformer_IED	,DI Description, D	I Owner, DI Li	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	 ▼ InstPeak 205274.209 205427.102 220.032 220.032 220.642 33662282.430 	** Input - Ind ************************************	Inst/ Inst/ 205274.209 Inst/ 204593.215 205427.102 225.220 220.032 220.032 220.042 93662282.4 93662282.4	< <	07:00
* 120217,065959421338,0,345_66kV,	_Transformer_JED	DI Description, D	I Owner, DI Li	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	A GOOSE Bina InstPeak 205274.209 204593.215 205427.102 220.642 93662282.430 98728138.820 98728138.820 9072	Phase -0.000* -0.00	4	<	07:00
▲ 120217,065959421338,0,345_66kV.	_Transformer_JED	,DI Description,D	I Owner, DI Lu	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	Construction of the second sec	**************************************	4	< ~	07:00
	Transformer JED	DI Description, D	I Owner, DI Lu	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	A GÖÖSE Bina 205274.209 205274.209 205427.102 225.220 220.642 39562282.430 39728138.820 0.027 -1.135	* 1000* * 0.000* * 0.00*		 	07:00
* 120217,065959421338,0,345_66kV,	Transformer_JED	DI Description, D	1 Owner,DI Li 12400	ocation, DR2	0250.DAT - 17	/02/2012 - 07:0	0:00.312 - Pri	mary - (Pea	k Type) J • 4 •	▲ GÖÖSE Bina InstPeak 204633.215 20462.102 225.220 20032 20032 20032 20032 20032 201642 33662282.430 93662282.430 93662282.430 93662282.430 93662282.430 93662282.430 93662282.430 93662282.430 9366282.430 9	Phase Phase Phase -0.000° -0.00° -0.000° -0.00° -0.000° -0.000° -0	Inst/ IX 205274.209 204593.215 204593.215 204642.2102 2255.220 225.220 220.642 39662282.41 39662282.41 3967278138.85 60.027 -1.135 SkV CB "e" switt_=		07:00
▲ 120217,065959421338,0,345_66kV, ▲ 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,065959421338,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06595942138,0,345_66kV, 120217,06507,06505420,0756000,0756000,0756000,07560000000000	Transformer JED	DI Description, D	1 Owner, DI La	ocation, DR2	0250.DAT - 17	/02/2012 - 07:0	00:00.312 - Pri	mary - (Pea	k Type) J • [1 •	▲ GÖÖSE Bina IntEPeak 204593.215 204593.215 204593.215 205427.102 225.20 225.20 20.642 20.032 20.042 39562282.430 9562282.430 9562282.430 9562282.430 9562282.430 9562282.430 9562282.430 9562582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.430 95762582.4300 95762582.430 95762582.430 95762582.430	Phase Phase Phase -0.000°			07:00
▲ 120217,065959421338,0,345_666V,	Transformer_JED	DI Description, D	1 Owner, DI Li	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	▲ GÖÖSE Bina InstPeak. 205274.209 20453215 205427102 225.201 220.032 220.032 220.032 20.042 9972813.830 9972813.830 ● OldeD Outor ▲ OldeD Outor ▲ DideD Outor	Phase Phase -0.000°	C C		07:00
* 120217,065959421338,0,345_66kV,	Transformer_JED	DI Description, D	I Owner, DI Lu	ocation, DR2_	0250.DAT - 17	/02/2012 - 07:0	0:00.312 - Pri	mary - (Pea	k Type)	A GOOSE Base InstPeak 205274.209 205427.102 205427.102 205427.102 205427.102 205427.102 20042 20042 20042 20042 39562282.430 96728138.820 60.027 1.135 A 245768V171 A 20180 Outco A DIOB Outco A DIO	Phase Phase -0.000°			0 7:00
* 120217,065959421338,0,345_66kV,	Transformer.JED	DI Description, D	1 Owner, DI Lu	ocation, DR2	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	▲ GÖÖSE Bina ■ IntiPeak. 205274.209 205274.209 205427.102 2252.20 220.022 220.022 220.022 200.021 200.021 201.022 201.021 201.021 201.022 201.021 201.021 201.022 201.021 201.021 201.021 201.021 201.021 201.021 201.022 201.021	Phase -0.000* -0.00*			07:00
× 120217,065959421338,0,345_66kV,	Transformer JED	DI Description, D	I Owner, DI Lu	r 2000	0250.DAT - 17	/02/2012 - 07:0	10:00.312 - Pri	mary - (Pea	k Type)	▲ GOOSE Bina ■ InttPeak. 205274.209 204633.215 205274.209 204633.215 205274.209 204633.215 205273.200 220.022 200.022 220.042 39652382.430 396723138.620 0.007 -1.135 ▲ 345/668V Tr. A 00000 Outcom ▲ DUBB Outcom A DUBB Outcom ▲ DUBB Outcom A DUBB Outcom ▲ DUBB Outcom A OUTB Outcom ▲ OUTB Outcom A OUTB Outcom	Phase Phase -0.000° -0.000° -0.000° -0.000° -0.000° -0.000° -0.000° N/A 180.000° N/A 180.000° t 2 t 3 t 4 4 y Input - Indé	IndW ● X IndW IndW ● X IndW IndW		> 07:00

Using WaveWin[®] software, successive records can be appended by opening both files and selecting "Append Open Files" under the File menu.

Note the use of the long file naming convention (file name of the lower recording is 120217,065959421338,0,345_kV_Transformer_IED,DI Description,DI Owner,DI Location,DR2_0250.DAT):

120217 = 2012, February 17

065959421338 = 06:59:59 (other digits take time-stamp down to the microsecond)

0 = time zone (not supported)

Other fields are populated from the Identity page in the Configurator

NovaTe





The result of appending 2 one-hour-long disturbance recordings. See the status change from Digital Output 13 (on to off) to Digital Output 12 (off to on) in the center of the screen capture at 08:00, with the 8-second overlap removed.

Incidental: Trace 10 is of some interest: See how the time sync error rises and falls, with occasional losses of sync (when trace #16 =0). This occurred because we used an internet-connected SNTP server in the demo. In a real substation with a clean network from the SNTP server to the recorders, trace 10 would be pretty flat, but this illustrates the functionality of the time-sync logic in use.

File Retrieval

BiView and the Retriever function within BiView can be used for manual or automatic file retrieval of SOE, Waveform, and Disturbance Records required to meet PRC-002.



) 🕈					BiView	v3.03
Connection	15						
Instantaneous Synchro Data (Raw Data (Virtual Disp Date/Time Vector Diap	gram	inge Rate:) Stop 5000 ‡ (m	() Disconnect	Generate Comtr Generate Comtr Sequence of Eve Action Servor Log	ade Files ents Windows
	View) Co	ntrol	Polling	Modem	Files	Windows
FTP - 21	6.164.167.	20 Recording Files		X			
				_			
File Name	Size	Date / Time	Attribu	^			
SOELOG.TXT	499,974	5/31/2012 9.00 AM	N/A				
DR2_0162.ZIP	1,890,688	5/28/2012 10:56 AM	N/A	3			
DR2_0163.ZIP	1,890,451	5/29/2012 12:56 AM	N/A				
DR2_0164.ZIP	2,060,223	5/30/2012 12:56 AM	N/A	-			
DR2_0165.ZIP	2,200,012	5/30/2012 2:57 PM	N/A				
DR2_0166.ZIP	1,961,465	5/31/2012 4:56 AM	N/A				
DR2_0147.ZIP	1,897,323	5/19/2012 4:56 PM	N/A				
DR2_0148.ZIP	1,887,400	5/20/2012 6:56 AM	N/A				
DR1_0204.ZIP	3,023	5/8/2012 9:27 AM	N/A				
WR1_0204.ZIP	179,741	5/8/2012 9:28 AM	N/A				
DR2_0149.ZIP	1,888,075	5/20/2012 8:56 PM	N/A				
DR1_0221.ZIP	2,960	5/21/2012 9.08 AM	N/A				
DR1_0205.ZIP	3,025	5/9/2012 11:15 PM	N/A				
WR1_0205.ZIP	199,319	5/9/2012 11:15 PM	N/A				
DR1_0206.ZIP	3,118	5/9/2012 11:15 PM	N/A				
WR1_0206.ZIP	199,780	5/9/2012 11:16 PM	N/A				
DB2 0151 7IP	2,071,431	5/22/2012 12:56 AM	N/A				
DHE_ODDE	3,173	5/10/2012 8:31 AM	N/A				
DR1_0207.ZIP		5/10/2012 P-21 AM	N/A				
DR1_0207.ZIP WR1_0207.ZIP	199,204	3/10/2012 0.31 MM					
DR1_0207.ZIP WR1_0207.ZIP DR1_0208.ZIP	199,204 3,924	5/10/2012 8:41 AM	N/A				
DR1_0207.ZIP WR1_0207.ZIP DR1_0208.ZIP WR1_0208.ZIP	199,204 3,924 309,792	5/10/2012 8:41 AM 5/10/2012 8:42 AM	N/A N/A				

BiView connecting to 70 Series for manual file download

liView v3.	.03
e Comtrade e of Events } Retrieval	e Files
nts I ion Table I s I	Add New Task Run Task Now Edit Existing Task Delete Task View All Tasks

Using the Automated File Retrieval (Retriever) function within BiView

NovaTech



L.	
Disturbance Monitoring Equipment for PRC-002	

NovaTech®

Types of Recorder to Down	load	2	×
	Select the type of files t	o download	
✓ Disturbance 1	✔ WaveForm 1	Voltage Fluctuation Table 1	
✓ Disturbance 2	VaveForm 2	Voltage Fluctuation Table 2	
Sequence of Events Log	✓ Trend	Error Log	
		< Back Next > Cancel]

BiView Retriever allows you to select the record files you want to download

When to Connect			X
	Select when	n to download files	
	Starting Date 6/ 1/2012 🗸	Starting Time 11:59 PM	
	Fr	equency	
	🔾 Daily 💽 We	eekly 🔘 Monthly	
		< Back Finish	Cancel

BiView Retriever lets you select the time/date and frequency to automatically download record files



NovaTech Utility Systems and Services

Overview and Capabilities

NovaTech has been successfully designing, delivering, and supporting utility systems and services for over 30 years, including custom panels and installation services for Bitronics instruments. The Utility Systems and Services staff in Lenexa, Kansas includes project engineers, SCADA engineers, panel assemblers, software engineers, quality engineers and training instructors. The Lenexa staff works with other NovaTech locations – in Bethlehem, PA; Owings Mills, MD; Aiken, SC; Shelby, NC and Quezon City in the Philippines - to coordinate field installation and commissioning.

Our 37,000 square foot facility in Lenexa features a professionally designed climate controlled manufacturing area, state of the art testing laboratories, and fully equipped engineering areas.

Systems and Engineering Services:	Support and Training Services:
 Programmable Logic Controller (PLC) Engineering Logic generation, testing, and documentation Mounting and wiring SCADA and HMI Engineering Conventional (PC-based) and Web-based SCADA Database generation Communications engineering HMI screen development RTU engineering Distribution Automation Systems Engineering Configuration for fault isolation and restoration Configuration of load checking logic Simulation and testing Communications / radio engineering Radio Systems Engineering Site survey System design Coordinate work with installation contractor Electrical Mechanical Relay "Upgrade" Services to configure, install, and commission Bitronics instruments alongside E/M relays to provide SCADA and recording. 	 NCare Services Agreement Training and support Annual protocol licenses Extended life-cycle Universal configurations Supply Chain and procurement programs Educational Services Customized Training Conducted on-site or at one of our training locations Technology Courses Product Courses Orion Automation Processor Distributed I/O Products Bitronics 70 Series IED Application Courses SEL® Relay Integration Email Math and Logic Webpage Design SER and Alarms Configuration Technology Courses Ethernet in Substations DNP3 Serial Communications
 Onsite Installation and Configuration Services Work with Utility personnel to install Bitronics and Orion products Perform point-by-point checkout Debug communications systems 	
 .001Hz Certification Service To satisfy NERC requirements for generation sites Return Bitronics instrument for testing and certification 	

NovaTe



About NovaTech

NovaTech designs and manufactures power measurement, communication, and automation products including the Bitronics® Instruments, Orion Substation Automation Platform, and the D/3® Distributed Control System. NovaTech has experienced solid growth as a result of our commitment to customer service, innovative products, and a level of customization unmatched by the competition. With global presence and over thirty years of experience, we are proud to be a trusted resource to clients in electric utility T&D, smart power distribution, agriculture, brewing, pharmaceuticals, bio-sourced and specialty chemicals, plastics, metals, and other essential industries. For additional information about NovaTech, LLC, please visit www.novatechweb.com.

Copyright © 2012 NovaTech, LLC. All rights reserved. NovaTech and Bitronics are registered trademarks of NovaTech, LLC. Wavewin is a registered mark of Softstuf, Inc. SEL is a registered trademark of Schweitzer Engineering Laboratories, Inc. The information in this literature is subject to change without notice and is not to be construed as a warranty. AN_DME.PRC-002-2_061512

Contact:

L

NovaTech, LLC	T: 610.9
Bitronics Measurement and Recording	F: 610.9
261 Brodhead Road	E: bitro
Bethlehem, PA 18017	www.no

97.5100 97.5450 nics@novatechweb.com ovatechweb.com

Disturbance Monitoring Equipment for PRC-002